



NOTE: IF EXTERIOR MOUNTED BREAKER AT METER BASE, USE 4 WIRE TYPE SE. CABLE FROM BREAKER(S) TO PANEL(S) IN BUILDING.

CONCEALED ENTRANCE PROHIBITED ABOVE METER BASE

CONSUMER OWNED SERVICE ENTRANCE SIZING				
DISCONNECT SIZE IN AMPS	SIZE COPPER SER. WIRE	SIZE ALUM. SER. WIRE	SIZE CONDUIT NOTE: * *	SIZE GROUND
100	NO. 4	NO. 2	2"	NO. 6
150	NO. 1	2/0	2"	NO. 6
200	2/0	4/0	2"	NO. 4
225	3/0	250	2 1/2"	NO. 2
250	4/0	300	2 1/2"	NO. 2
300	250	350	3"	NO. 2
400	400	600	3"	1/0
600	500	750	3 1/2"	1/0

THIS CHART IS FOR SINGLE RESIDENCE CONSTRUCTION ONLY, SINGLE PHASE.
 * * NOTE: 2 1/2" MINIMUM FOR UNDERGROUND.
 NOTE: LOCAL CODE AUTHORITIES MAY HAVE ADDITIONAL REQUIREMENTS TO THOSE GIVEN HERE.

REVISED: OCT. 29, 1997 MJM

ALL MATERIAL SHOWN ON DRAWINGS TO BE FURNISHED BY CUSTOMER UNLESS OTHERWISE NOTED.

METER BASE INSTALLATION OVERHEAD

REVISED: JAN. 95	JAN. 99	DATE: MAY 1989	AMICALOLA E.M.C. JASPER, GA.	DRAWING NO. SPEC7
DRAWN BY: MARVIN MOORE		APPROVED BY: RAY ROBERTS		